Massachusetts Fire Training Council Firefighter Practical Certification Examination

| Skill Sheet No. FF-I- 408 01-01-05 Candidate Number | | | | | | | | | |
|---|-----------|--|------------------------------|------|--|---|--|---|--|
| Skill Title: REPLACE A SECTION IN A CHARGED LINE | | | | | | | | | |
| NFPA Objective: 5.3.10 Minimum to pass 7 | | | | | | | | | |
| PERFORMANCE: | | | | | | | | F | |
| 1 AUD ID (4) E : (/DDE): | | | | | | | | | |
| | 1. 2. | All Personal Protective Equipment (PPE) is properly worn. | | | | | | | |
| _ | 4. | Applies a hose clamp on the supply side approximately 3-5 feet from the coupling of the hose to be replaced. | | | | | | | |
| | 3. | Assures hose is centered in jaws of clamp. | | | | | | | |
| | 4. | Carries two new sections of hose to the site of replacement. | | | | | | | |
| | 5. | Uncouples the damaged section of hose utilizing either the foot-tilt or the | | | | | | | |
| | | over-hip method. | | | | | | | |
| | 6. | Removes damaged sections. | | | | | | | |
| | 7. | Replaces damaged section with both replacement hoses until hand-tight. | | | | | | | |
| | 8. | Slowly releases the hose clamp. | | | | | | | |
| | 9. | Straighten | ns the hoseline to remove ki | nks. | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | | | | | | - | | | |
| | | | | | | | | | |
| | | | | | | | | | |
| | I | <u> </u> | | | | | | 1 | |
| | | | | | | | | | |
| | | | | | | | | | |

| Failure of this critical portion is cause for entire skill failure | | | | | | | |
|--|-------|--|--|--|--|--|--|
| Examiner Signature | Date/ | | | | | | |